

Pl. inform the
organisers
about
2/2
DGM (BDD).

**India Trade Promotion Organisation
(Electrical Unit)**

Ref No.168-ITPO (12)/Engg./Elect./2021-22/3057


Date: 05.01.2022

CIRCULAR

It is notified to all concerned that the total power load available in New Halls 2-5 (Ground Floor & First Floor) is as under. Fair division may inform the event organizers and make allotment of power load accordingly. In ITPO events each stall of area 12 Sq.mtr under shell scheme will be provided 5 Spot lights of 20 Watt each and a power point of 5/15 Amp. All to note that the 1 KW per stall provision is not automatic and should be decided in consultation with Engineering Division.

Sl. No	Hall No.	Power load available	Remarks
1.	2 (Ground Floor)	160 KW	4 Nos Floor Panels of capacity 40 KW each.
2.	2 (First Floor)	160 KW	4 Nos Floor Panels of capacity 40 KW each.
3.	3 (Ground Floor)	160 KW	4 Nos Floor Panels of capacity 40 KW each.
4.	3 (First Floor)	160 KW	4 Nos Floor Panels of capacity 40 KW each.
5.	4 (Ground Floor)	160 KW	4 Nos Floor Panels of capacity 40 KW each.
6.	4 (First Floor)	160 KW	4 Nos Floor Panels of capacity 40 KW each.
7.	5 (Ground Floor)	280 KW	4 Nos Floor Panels of capacity 70 KW each.
8.	5 (First Floor)	280 KW	4 Nos Floor Panels of capacity 70 KW each.


This issues with the approval of the Competent authority.



05/01/22
(Sanjay Azad)

Copy to:

Sr. Manager (Elect.)

1. OSD
2. GM (BDD)
3. GM (HM)
4. GM (SRS)
5. GM (Security)
6. C (KMS)
7. DGM (BL)


DGM (SRS)
02/02/2022


02/02/2022
DGM (SRS)